

*Annual Drinking Water Quality Report for 2018
Village of Ellenville
2 Elting Court
Ellenville NY, 12428
(Public Water Supply ID# 5503366)*

INTRODUCTION

To comply with State regulations, Village of Ellenville, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact **Michael Avery Jr., Senior Water Treatment Operator at 647-5740, or Village Clerk, at 647-7080.** We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled village board meetings. The meetings are held on the second and fourth Monday every month, at the Ellenville Government Center, 2 Elting Court, Ellenville NY, 12428.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The Village of Ellenville receives water from four sources; these include one surface water supply (North Gully Reservoir) which is only used in extreme emergencies and three well supplies (Fallsview well, Harris well, and Center St. well.). The surface supply receives water from Lake Maratanza through a 10-inch water main that is connected to North Gully Brook and transported into the reservoir. The reservoir has a capacity of 1.5 million gallons. Water from the reservoir is filtered by bag filters followed by two stage cartridge filtration, disinfected with liquid sodium hypochlorite and then pumped to a 150,000 gallon holding tank for chlorine contact time requirements. Zinc orthophosphate is also added to the filtered water supply for corrosion control in the distribution system.

Water from the wells supplies currently receive chlorination treatment with liquid sodium hypochlorite. Plus we have to add Zinc orthophosphate and Sodium Hydroxide for the corrosion control. The Fallsview Well has a capacity of 500 gallons per minute (gpm) and the Harris Well has a capacity of about 620 gpm. The new Harris Well (NO. 2) has become a primary source and the Center Street Well being used as backup or as an emergency source supply.

Once Treated, all source waters (wells and surface supply) enter the Village's distribution system. The distribution system currently operates with two in-Village water storage tanks with a total capacity of 1.1 million gallons and two booster pump stations that are located on Westwood Ave. and Mountain Ave.

Source Water Assessment

The NYSDOH has completed a source water assessment for the 3 well sources of this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. While nitrates were detected in our water, it should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants from natural sources. The presence of contaminants does not necessarily indicate that the water poses a health risk. See section " Are there contaminants in our drinking water? " for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As mentioned before, three of the sources from which our water is derived are drilled wells. The source water assessment has rated these wells as having a medium to high susceptibility to some microbial; and low to no susceptibility to nitrates, industrial solvents, and other industrial contaminants. These ratings are due primarily to low intensity residential activities in the assessment area. In addition, the wells draw from fractured bedrock and a lower permeability layer exists above the aquifer. Please note that, while the source water assessment rates our wells as being susceptible to some microbial, our water is disinfected to ensure that the finished water delivered into your home meets the New York State drinking water standards for microbial contamination.

A copy of this assessment, including a map of the assessment area, can be obtained by contacting the Village Water Department.

FACTS AND FIGURES

The Village of Ellenville supplies water to approximately 4,300 people through 1,362 service connections. The number of service connections include commercial accounts as well as residences. The total amount of finished water produced in 2018, was 354,131,000 gallons or an average of 0.900 million gallons per day (mgd). The highest daily usage of water was in July with a use of .970 mgd; the lowest daily usage was in February with a use of 0.825 mgd. The amount of water delivered to customers in 2018 was 256,538,313 gallons. This leaves a non billable total of 97,592,687 gallons or 27% . This non billable water was due to flushing water mains, fire fighting, water main breaks, recreation, street sweeping and illegal use.

Water rates

Water bills are sent out on a quarterly basis. Current residential water rates for the Village of Ellenville are \$56.00 for the first 5000 gallons and \$5.00 per 1000 gallons over the minimum usage.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include total coliform, turbidity, inorganic compounds (IOC'S), principal organic contaminants (POC'S), synthetic organic compounds (SOC'S), nitrate (NO₃), nitrite (NO₂), lead and copper, and radiological parameters (gross alpha emitters and radium). The NYS Department of Health allows us to test for some contaminants less than once a year because the concentrations of these contaminants do not change frequently. Therefore some of our data, though representative, is more than a year old.

According to State regulations, the Ellenville Water Department routinely monitors your drinking water for various contaminants. A summary of the contaminants detected last year is provided in Table 1. Contaminants that

were tested for, but not detected, are not listed in the table. These contaminants that were not detected are: principle organic chemicals, synthetic organic chemicals, arsenic, cadmium, chromium, mercury, selenium, fluoride, antimony, beryllium, nickel, thallium, cyanide, iron, color, silver, gross alpha radiation, and radium 226.

The testing schedule was in accordance with the yearly monitoring requirements stipulated by the NYS Department of Health and the Ulster County Health Department. In 2017, the Village continued testing for disinfection by-product compounds known as trihalomethanes (TTHM'S) and haloacetic acids (HAA5). The disinfection by-products are compounds that may form when disinfectants (such as chlorine) are added to drinking water to kill germs that react with naturally occurring organic matter in the water. Samples for TTHM and HAA5 analyses are collected from a furthest point in the distribution system in accordance with the NYSDOH sampling requirements. The furthest point is used because it provides a measure of the possible maximum TTHM and HAA5 concentrations that could develop throughout all of the Village water distribution system. Radiological contaminants were tested for in 2016 and are included in Table 1.

It should be noted that all drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the US EPA'S safe drinking water hotline (1-800-426-4791), the NYS Department of Health- Office of public health (518-793-3893) or the Ulster County Health Department (845-340-3010). Information is also available through the US EPA'S drinking water website (www.epa.gov/safewater/hfacts.html) and the NYSDOH website (www.health.state.nv.us).

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper volatile organic compounds, total trihalomethanes, and synthetic organic compounds. None of the compounds we analyzed for were detected in your drinking water.

TABLE 1. - LIST OF DETECTED CONTAMINANTS IN 2017

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MC LG	REGULATOR Y LIMIT (MCL,TT,AL)	Likely Source of Contamination
Total Coliform Bacteria	No	FIVE SAMPLES MONTHLY	NO POSITIVE SAMPLES	N/A	N/A	MCL 2 OR MORE PER MONTH	Naturally present in the environment
COPPER (AT CUSTOMER TAP)	No	8/29/18 90 th Percentile	0.12 0.68 0.60	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives
LEAD (AT CUSTOMER TAP)	NO	90 th Percentile	<0.001 0.004 0.002	mg/l	0	AL = 0.015	Corrosion of household plumbing systems; Erosion of natural

TABLE 1. - LIST OF DETECTED CONTAMINANTS IN 2017

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MC LG	REGULATOR Y LIMIT (MCL,TT,AL)	Likely Source of Contamination
							deposits
CHLORIDE Center St Well	No	6/26/15	16.4	mg/l	N/A	MCL= 250	Naturally occurring or indicative of road salt contamination.
NITRATE CENTER ST FALLSVIEW HARRIS WELL	NO	11/29/18	0.82 0.63 0.82	mg/l	10	MCL= 10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
MANGANESE Harris Center St Fallsview	NO	6/26/15	0.23	mg/l	N/A	MCL= 0.3	Naturally occurring; Indicative of landfill contamination.
BARIUM Center St Well HARRIS WELL Fallsview Well	No	11/29/18	0.029 0.032 0.027	mg/l	2.0	MCL= 2.0	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
TOTAL TRihalometh ANES (TTHM'S)	NO	8/29/18 Dunkin Donut 29 Mountain Ave..	16.5 11.3	ug/l	N/A	MCL= 80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
HALOACETIC ACIDS (HAA5)	NO	8/29/18 Dunkin Donut 29 Mountain	7.6 9.3	ug/l	N/A	MCL=60	By-product of drinking water disinfection need

TABLE 1. - LIST OF DETECTED CONTAMINANTS IN 2017

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	REGULATORY LIMIT (MCL,TT,AL)	Likely Source of Contamination
RADIUM 228 CENTER ST WELL	NO	06/26/15	0.06	PCI/L	0	MCL=5 PCI/L	EROSION OF NATURAL DEPOSITS

Notes:

1 – Although there is no MCL for sodium, it is recommended that those on a severely sodium restricted diets not consume water that contains more than 20 mg/l of sodium. The recommend limit for those on a moderately restricted sodium diets is 250 mg/l.

2 - If you collect 20 or more rank the results from the lowest to the highest value, numbering each from 1 up samples... to the number of samples taken. Multiply the number of samples taken by 0.9. The resulting number is the value that is the 90th percentile.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

Picograms per liter (pg/l): Corresponds to one part per of liquid to one quadrillion parts of liquid (parts per quadrillion – ppq).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

Millirems per year (mrem/yr): A measure of radiation absorbed by the body.

Million Fibers per Liter (MFL): A measure of the presence of asbestos fibers that are longer than 10 micrometers.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During 2016, we also tested for a group of Synthetic Organic Chemicals (SOC's), and all results came back well below state requirements.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- ◆ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, Then check the meter after 15 minutes, If it moved, you have a leak.

SYSTEM IMPROVEMENTS

In 2018 we continued the implementation of improvements to allow better corrosion control in our treatment facilities. This will result in a reduction in lead and copper levels in our water and extend the life of our buried water lines. We also completed the installation of a new water transmission main from the Fallsview and Harris

wells to the distribution system. This will increase our ability to pump water from the wells to the rest of the Village water system and increase the reliability of the entire water system .

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.